



जिला जल जाँच प्रयोगशाला  
लोक स्वा० प्रमंडल, औरंगाबाद  
निर्गत सं०.....५२.....  
तिथि.....१५/०४/२०२५

**PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

It is certified that an inspection team headed by **Md. Shami Akhtar Executive Engineer.**  
(Name of Officer with designation) from **PHED P.H. Division Aurangabad.** (Name of  
Department/Office) inspected **Gyan Ganga National School Bel More Aurangabad.** (Name  
and Address of the School) on **12.04.2025** (Date of Inspection) and found that the **Gyan  
Ganga National School Bel More Aurangabad.** (Name of School) has safe drinking water  
facilities for the student and members of staff of the institution and is maintaining the  
hygienic sanitation condition in the school building & the campus as per norms prescribed  
by the Central/State/U.T. Govt.

The above is valid for a period of **Six months.**

*All tested Parameters are  
in permissible limit.*

*Shailena*  
*15.04.25*

Chemist  
P.H. Div. Aurangabad  
**Chemist**  
**P.H Division**  
**Aurangabad**

*[Signature]*  
*15/04/25*  
Assistant Engineer  
**Technical Manager**  
P.H. Div. Aurangabad  
**Com**  
**Assistant Engineer**  
**P.H. Division, Aurangabad**

*[Signature]*  
*15/4/25*  
Signature with Seal: .....  
Name .....  
Designation .....  
Name & Address of the officer/ Department.....  
**Quality Manager**  
**Cum**  
**Executive Engineer**  
**P.H Division, Aurangabad**

To

**Gyan Ganga National School**  
**Bel More Aurangabad.**



Government of Bihar  
District Level Water Testing Laboratory  
P.H. Division, Aurangabad

जिला जल जाँच प्रयोगशाला  
लोक स्वास्थ्य प्रमंडल, औरंगाबाद  
निर्गत सं०.....५३८.....  
तिथि.....१५/०४/२०२५

Sample sent to Lab by :- Sample taker Sri Rakesh kumar  
Sample Submitted in Lab on date :-12.04.2025

District Name:- Aurangabad

S. N.	Block	Panchayat	Location of source	Chemical Parameters												
				p.H	Tur	EC	TDS	TH	Ca	Mg	ALK	Cl	Fe	SO <sub>4</sub>	F	T. Coli.
1	Obra	Bel	Gyan Ganga National School Bel More Aurangabad	7.47	0.14	874	568	238	58	22.31	312	25.97	0.31	20	0.53	Negative
Acceptable Limit (IS 10500:2012)				6.50	1	-	500	200	75	30	200	250	1	200	1.0	<1.1
Maximum Permissible Limit in absence of alternate source				8.50	5 NTU	-	2000	600	200	100	600	1000	NR	400	1.5	NR

All Tested Parameter are in Permissible Limit.

Shailendra  
15.04.25  
Chemist

P.H. Division Aurangabad  
**Chemist**  
P.H Division  
Aurangabad

Assistant Engineer  
P. H. Division Aurangabad  
**Technical Manager**  
Com

Assistant Engineer  
P.H. Division, Aurangabad

Executive Engineer  
P. H. Division Aurangabad  
**Quality Manager**  
Cum  
Executive Engineer  
P.H Division, Aurangabad